CM-IWS.2P 1/4



PRODUCT-DETAILS

## CM-IWS.2P

## CM-IWS.2P Insulation monitoring relay 1c/o, 1-100kOhm, 24-240VAC/DC



General Information	
Extended Product Type	CM-IWS.2P
Product ID	1SVR740670R0200
EAN	4016779852654
Catalog Description	CM-IWS.2P Insulation monitoring relay 1c/o, 1-100kOhm, 24-240VAC/DC
Long Description	The CM-IWS.2P serves to monitor insulation resistance in accordance with IEC 61557-8 in unearthed IT AC systems with a voltage up to 400 V AC. The CM-IWS.2 can be configured to the requirements of the applications and therefore used multifunctional.

Ordering	
EAN	4016779852654
Minimum Order Quantity	1 piece
Customs Tariff Number	85364900

## **Popular Downloads**

Data Sheet, Technical 2CDC112196D0201

2/4 CM-IWS.2P

Information	
Instructions and	1SVC730550M0001
Manuals	
CAD Dimensional	2CDC001079B0201
Drawing	

Dimensions	
Product Net Width	22.5 mm
Product Net Height	85.6 mm
Product Net Depth / Length	103.7 mm
Product Net Weight	0.13 kg

Technical		
Function		Unearthed AC systems Up to 400 V AC
Measuring Range		1 100 kΩ
Rated Control Supply Voltage (U <sub>S</sub> )		24 240 V AC/DC
Rated Frequency (f)		Measuring Circuit DC Hz Measuring Circuit 15 400 Hz Supply Circuit 50/60 Hz
Output		1 c/o (SPDT) contact
Terminal Type		Screwless Terminals
Rated Operational Current AC-12 (I <sub>e</sub> )		(230 V) 4 A
Rated Operational Current AC-15 (I <sub>e</sub> )		(230 V) 3 A
Rated Operational Current DC-12 (I <sub>e</sub> )		(24 V) 4 A
Rated Operational Current DC-13 (I <sub>e</sub> )		(24 V) 2 A
Minimum Switching Capacity		24 V 10 mA
Rated Impulse Withstand Voltage (U <sub>imp</sub> )		asuring Circuit / Output Circuit 6 kV pply Circuit / Measuring Circuit 6 kV Supply Circuit / Output Circuit 6 kV
Rated Insulation Voltage (U <sub>i</sub> )	Sup	suring Circuit / Output Circuit 400 V ply Circuit / Measuring Circuit 400 V Supply Circuit / Output Circuit 300 V
Degree of Protection		Housing IP50 Terminals IP20
Overvoltage Category		III
Pollution Degree		3
Short-Circuit Protective Devices		Output Circuit NC - F Type Fuses 6 A Output Circuit NO - F Type Fuses 10 A
System Leakage Capacitance ( $C_E$ )		10 μF
Electrical Durability		AC-12 100000 cycle
Mechanical Durability		30000000 cycle
Connecting Capacity		Flexible with Ferrule 2x 0.5 1.5 mm <sup>2</sup> th Insulated Ferrule 2x 0.5 1.5 mm <sup>2</sup> Flexible 2x 0.5 1.5 mm <sup>2</sup> Rigid 2x 0.5 1.5 mm <sup>2</sup>
Wire Stripping Length		8 mm
Recommended Screw Driver		0.8 x 4
© 2024 ABB. All rights reserved.	2024/04/12	Subject to chang

CM-IWS.2P 3/4

Mounting Position	16
Mounting on DIN Rail	TH35-15 (35 x 15 mm Mounting Rail) acc. to IEC 60715 TH35-7.5 (35 x 7.5 mm Mounting Rail) acc. to IEC 60715
Standards	CAN/CSA C22.2 No.14 IEC/EN 63000 IEC/EN 61326-2-4 IEC/EN 61557-1 IEC/EN 61557-8 UL 508

Technical UL/CSA	
Maximum Operating Voltage UL/CSA	Output Circuit 300 V AC
Contact Rating UL/CSA	B300
Connecting Capacity UL/CSA	Flexible 2x 18-16 AWG Rigid 2x 20-16 AWG
Pilot Duty UL/CSA	B300
Flammability According to UL94	V-0

Environmental	
Ambient Air Temperature	Operation -25 +60 °C Storage -40 +85 °C
Maximum Operating Altitude Permissible	Without Derating 2000 m

Material Compliance	
Conflict Minerals Reporting Template (CMRT)	9AKK108467A5658
REACH Declaration	1SVD981001-4501
RoHS Information	1SVD981001-4401
RoHS Status	Following EU Directive 2011/65/EU
Toxic Substances Control Act - TSCA	2CMT2023-006536

Circular Value	
End of Life Instructions	1SAC200290H0001

Certificates and Declarations	
CB Certificate	CB_DK-30302-A1-UL
CCC Certificate	CCC_2010010303438770
CQC Certificate	CQC2010010303438770
cULus Certificate	cULus508_20120727-E140448
Declaration of Conformity - CCC	2020980303000184
Declaration of Conformity - CE	1SVD981011-00
Declaration of Conformity - UKCA	1SVD981011-10

CM-IWS.2P 4/4

DNV GL Certificate DNV\_GL\_TAA000017C

EAC Certificate EAC\_RU\_C-DE.ME77.B.03424

Container Information	
Package Level 1 Units	box 1 piece
Package Level 1 Width	97 mm
Package Level 1 Depth / Length	30 mm
Package Level 1 Height	109 mm
Package Level 1 Gross Weight	0.155 kg
Package Level 1 EAN	4016779852654

Classifications	
Object Classification Code	В
ETIM 7	EC001444 - Insulation and earth fault monitoring relay
ETIM 8	EC001444 - Insulation and earth fault monitoring relay
ETIM 9	EC001444 - Insulation and earth fault monitoring relay
eClass	V11.0 : 27371807
UNSPSC	39122331
E-Number (Finland)	2712261
E-Number (Sweden)	3860660

## Categories

 $Low\ Voltage\ Products\ \rightarrow \ Low\ Voltage\ Products\ \rightarrow \ Low\ Control\ Products\ \rightarrow \ Electronic\ Relays\ and\ Controls\ \rightarrow\ Insulation\ Monitors$ 





