

PRODUCT-DETAILS

CM-PSS.41P CM-PSS.41P Three-phase monitoring relay 2c/o, 0,0.1-30s, L1-L2-L3=3x400VAC



Extended Product Type	CM-PSS.41P
Product ID	1SVR740784R3300
EAN	4016779852005
Catalog Description	CM-PSS.41P Three-phase monitoring relay 2c/o, 0,0.1-30s, L1-L2-L3=3x400VAC
Long Description	The CM-PSS.41P relay is from the CM three-phase monitors range. This relay operates with a rated control supply voltage / three-phase measuring voltage of 400 V AC and has a 2 c/o output with contacts rated at 250 V / 4 A. The CM-PSS.41P monitors the phase parameters over/undervoltage and phase failure. Phase sequence monitoring as well as an ON or OFF tripping delay are selectable. The tripping delay is adjustable over a range of instantaneous to 30 s (0, 0.1-30 s). A sealable transparent cover for protection against unauthorized changes is available as accessory. The device offers maintenance free Easy Connect Technology with push-in terminals.

Ordering	
EAN	4016779852005
Minimum Order Quantity	1 piece
Customs Tariff Number	85364900

Popular Downloads

© 2024 ABB. All rights reserved.

Data Sheet, Technical Information	2CDC112178D0201
Instructions and Manuals	1SVC730730M1000 1SVC730730M0000
CAD Dimensional Drawing	2CDC001079B0201

Dimensions	
Product Net Width	22.5 mm
Product Net Height	85.6 mm
Product Net Depth / Length	103.7 mm
Product Net Weight	0.123 kg

Technical Function	Phase failure detection
Function	Phase railute detection Phase sequence monitoring Over- and undervoltage monitoring
Measuring Range	(L-L) 360 440 V AC
Time Range	200 ms start-up delay 0 s or 0.1 30 s tripping delay (ON or OFF)
Rated Control Supply Voltage (U _s)	(L-L) 400 V AC
Rated Frequency (f)	Supply Circuit 50/60 Hz
Output	2 c/o (SPDT) contacts
Terminal Type	Screwless Terminals
Rated Operational Current AC-12 (I _e)	(230 V) 4 A
Rated Operational Current AC-15 (I _e)	(230 V) 3 A
Rated Operational Current DC-12 (I _e)	(24 V) 4 A
Rated Operational Current DC-13 (I _e)	(24 V) 2 A
Minimum Switching Capacity	24 V 10 mA
Rated Impulse Withstand Voltage (U _{imp})	Input Circuit 6 kV Output Circuit 4 kV
Rated Insulation Voltage (U _i)	Input Circuit / Output Circuit 600 V Output Circuit 1 / Output Circuit 2 300 V
Degree of Protection	Housing IP50 Terminals IP20
Overvoltage Category	
Pollution Degree	3
Short-Circuit Protective Devices	Output Circuit NC - F Type Fuses 6 A Output Circuit NO - F Type Fuses 10 A
Electrical Durability	AC-12 100000 cycle
Mechanical Durability	3000000 cycle
Connecting Capacity	Flexible with Ferrule 2x 0.5 1.5 mm² Flexible with Insulated Ferrule 2x 0.5 1.5 mm² Flexible 2x 0.5 1.5 mm² Rigid 2x 0.5 1.5 mm²
Wire Stripping Length	8 mm
Mounting Position	16
Mounting on DIN Rail	TH35-15 (35 x 15 mm Mounting Rail) acc. to IEC 60715 TH35-7.5 (35 x 7.5 mm Mounting Rail) acc. to IEC 60715
Standards	CAN/CSA C22.2 No.14 IEC/EN 63000 IEC/EN 60255-27 IEC/EN 61000-6-2 IEC/EN 61000-6-3

	UL 508
Technical UL/CSA	
Maximum Operating	Output Circuit 300 V AC
Voltage UL/CSA Contact Rating UL/CSA	B300
Connecting Capacity	Flexible 2x 18-16 AWG
UL/CSA	Rigid 2x 20-16 AWG
Pilot Duty UL/CSA	B300
Flammability According to UL94	V-0
Environmental	
Ambient Air Temperature	Operation -25 +60 °C
	Storage -40 +85 °C
Maximum Operating Altitude Permissible	Without Derating 2000 m
Material Compliance	
	0.41/1/1.00.407.4 505.0
Conflict Minerals Reporting Template (CMRT)	9AKK108467A5658
REACH Declaration	1SVD981001-4501
RoHS Information	1SVD981001-4401
RoHS Status	Following EU Directive 2011/65/EU
Toxic Substances Control Act - TSCA	2CMT2023-006536
Circular Value	
End of Life Instructions	1SAC200290H0001
Certificates and Declarations	
CQC Certificate	CQC2009010303326655
cULus Certificate	cULus508_20120829-E140448
Declaration of Conformity - CCC	2020980303000197
Declaration of Conformity - CE	1SVD981014-00
Declaration of Conformity - UKCA	1SVD981014-10
DNV GL Certificate	DNV GL TAA000017D
Container Information	
Package Level 1 Units	box 1 piece
Package Level 1 Width	97 mm
Package Level 1 Depth / Length	30 mm
Package Level 1 Height	109 mm
Package Level 1 Gross Weight	0.148 kg
Package Level 1 EAN	4016779852005

© 2024 ABB. All rights reserved.

2024/04/12

Subject to change without notice

Classifications	
Object Classification Code	В
ETIM 7	EC001441 - Phase monitoring relay
ETIM 8	EC001441 - Phase monitoring relay
ETIM 9	EC001441 - Phase monitoring relay
eClass	V11.0 : 27371803
UNSPSC	39122332
E-Number (Finland)	2712289
E-Number (Sweden)	3860601

Categories

Low Voltage Products and Systems \rightarrow Control Products \rightarrow Electronic Relays and Controls \rightarrow Three Phase Monitors

