

PRODUCT-DETAILS

QA/S3.16.1

QA/S3.16.1 Energy Analyzer, M-Bus, 16 Devices, MDRC



General Information	
Extended Product Type	QA/S3.16.1
Product ID	2CDG110226R0011
EAN	4016779997751
Catalog Description	QA/S3.16.1 Energy Analyzer, M-Bus, 16 Devices, MDRC
Long Description	Energy management solution for capturing and analyzing consumption data of up to 16 electricity, gas, water or heat meters via M-Bus. Web-based user interface with graphical analysis functions such as historical data, dashboard, and more. Various export functions and APIs for further processing of metering data.
Installation	00000144000000
Instructions and Manuals	2CDG941193P0001
Mounting Type	DIN-Rail
Technical	
Data Sheet, Technical Information	2CDC512091D0201
Maximum Number of Switching Outputs	0

QA/S3.16.1 2/3

Compatible Bus Systems		m-Bus	
Product Range		KNX	
Connection Type		Direct	
Manual Operation		No	
Number of Batteries		0	
Electrical			
/oltage Range		110 230 V AC	
Auxiliary Voltage AC/DC		230 V AC	
Power Loss		3 W	
Design			
Color		light grev	
Material Compliance ROHS Information		2CDKE12002D2701	
RoHS Status	2CDK512092D2701 Following EU Directive 2011/65/EU		
REACH Declaration	Following EU Directive 2011/65/EU 9AKK108468A9644		
REACH Information	True - contains substances > 0.1 mass percentage		
Conflict Minerals	True - contains	9AKK108468A3363	
Reporting Template CMRT)		37 HAY 100-100/10000	
Degree of Protection		IP20	
Dimensions			
Width in Number of Modular Spacings		4	
Product Net Width		72 mm	
Product Net Height	90 mm		
Product Net Depth /	64.5 mm		
ength Product Net Weight		0.15 kg	
Built-In Depth (t ₂)	64.5 mm		
Dimension Diagram		2CDC072033F0015	
Certificates and Declarations			
		200//51200202701	
Declaration of Conformity CE		2CDK512092D2701	
Classifications			
ETIM 9	EC001102 - Energy management for bus system		
eClass		V11.0 : 27143126	
Object Classification Code	A		
VEEE Category	5. Small Equipment (No External Dimension More Than 50 cm)		
VEEE B2C / B2B		Business To Consumer	
2024 ABB. All rights reserved.	2024/04/12	Subject to chan	

QA/S3.16.1 3/3

Categories

 $Low\ Voltage\ Products\ and\ Systems \rightarrow Building\ and\ Home\ Automation\ Solutions \rightarrow KNX \rightarrow Energy\ Management \rightarrow Energy\ Gateways\ and\ Analysers$





