

PRODUCT-DETAILS

F202 A-25/0.1 F202 A-25/0.1 Residual Current Circuit Breaker 2P Type A 100 mA



| General Information | | |
|---|---|--|
| Extended Product Type | F202 A-25/0. | |
| Product ID | 2CSF202101R2250 | |
| EAN | 8012542786900 | |
| Catalog Description | F202 A-25/0.1 Residual Current Circuit Breaker 2P Type A 100 m/ | |
| The RCCBs F200 series assures protection to people and installa Long Description current to earth. A large offer for standard instantaneous and selec is completed with some configurations for s | | |
| ABB EcoSolutions | | |
| ABB EcoSolutions | Ye | |
| | | |
| | | |
| Circular Value | | |

End of Life Instructions

© 2024 ABB. All rights reserved.

9AKK108468A4361

2024/04/12

Subject to change without notice

Eco Transparency

Environmental Product Declaration - EPD 9AKK108467A3700

| Standards | IEC/EN 61008 UL 1053 |
|---|--|
| Type of Residual Current | Type A |
| Rated Voltage (Ur) | 230 V |
| Rated Operational Voltage | 230 V |
| Rated Insulation Voltage (Ui) | 500 V |
| Rated Impulse Withstand Voltage (U _{imp}) | 4 kV |
| Input Voltage Type | AC |
| Rated Current (In) | 25 A |
| Rated Residual Current | 100 mA |
| Rated Conditional Short- Circuit Current (I _{nc}) | 10 kA |
| Rated Service Short- Circuit Breaking Capacity (I _{cs}) | 1 kA |
| Leakage Current Type | A |
| Rated Frequency (f) | 50 60 Hz |
| Power Loss | at Rated Operating Conditions per Pole 1 W |
| Power Supply Connection | Arbitrary |
| Electrical Endurance | 10000 cycle |
| Number of Poles | 2 |
| Operating Characteristic | Instantaneous |
| Mounting Type | DIN-Rail |
| Options Provided | None |
| Accessories Available | Yes |
| Connecting Capacity | Busbar 10 mm ² Rigid 25 25 mm ² Flexible 25 25 mm ² |
| Rated Cross-Section | 4 - Multi-Wired 025 mm² 1 - Solid-Core 2525 mm² |

| Material Compliance | |
|---|--|
| RoHS Information | 9AKK106713A5602 |
| RoHS Status | Following EU Directive 2011/65/EU and Amendment 2015/863 July 22, 2019 |
| RoHS Date | 20211115 |
| REACH Declaration | 9AKK108467A9482 |
| Conflict Minerals Reporting Template (CMRT) | 9AKK108468A3363 |

© 2024 ABB. All rights reserved.

Subject to change without notice

| Environmental | | | |
|--|---|--|--|
| Ambient Temperature | -2555 °C | | |
| Ambient Air | Operation -2555 °C | | |
| Temperature Degree of Protection | IP2X | | |
| Pollution Degree | 2 | | |
| Resistance to Vibrations | 20 Cycles with Load 0.8 In: 1g or 1mm 50 150 5 Hz | | |
| Resistance to Shock acc. | 25g 2 shocks 13 ms | | |
| to IEC 60068-2-27 | 25g 2 5100k5 15 115 | | |
| Environmental Information | Refer to RoHS | | |
| Technical UL/CSA | | | |
| Maximum Operating Voltage UL/CSA | 277 V AC | | |
| Short-Circuit Current Rating (SCCR) | 100 mA | | |
| Dimensions | | | |
| Width in Number of Modular Spacings | 2 | | |
| Product Net Width | 0.035 m | | |
| Product Net Height | 0.085 m | | |
| Product Net Depth / | 0.069 m | | |
| Length | | | |
| Product Net Weight | 0.200 kg | | |
| Built-In Depth (t ₂) | 69 mm | | |
| Ordering | | | |
| Package Level 1 Units | box 1 piece | | |
| Package Level 1 Gross Weight | 0.235 kg | | |
| Certificates and Declarations | | | |
| Declaration of Conformity - CE | 9AKK106713A5602 | | |
| Installation | | | |
| Instructions and Manuals | 9AKK107991A6127 | | |
| Popular Downloads | | | |
| Data Sheet, Technical Information | 9AKK107991A8329 | | |

Subject to change without notice

| Classifications | | | | |
|---------------------------------------|--|--|--|--|
| ETIM 8 | EC000003 - Residual current circuit breaker (RCCB) | | | |
| ETIM 9 | EC000003 - Residual current circuit breaker (RCCB) | | | |
| WEEE Category | 5. Small Equipment (No External Dimension More Than 50 cm) | | | |
| WEEE B2C / B2B | Business To Consumer | | | |
| CN8 | 85363030 | | | |
| UNSPSC | 39121601 | | | |
| eClass | V11.0 : 27142201 | | | |
| IDEA Granular Category Code (IGCC) | 4875 >> Residual current circuit breaker (RCCB) | | | |
| Object Classification Code | F | | | |

Accessories

| Identifier | Description | Туре | Quantity | Unit Of Measure |
|-----------------|--|-------------------|----------|--------------------|
| 2CDS200912R0001 | S2C-H6R Auxiliary Contact | S2C-H6R | 2 | piece |
| 2CDS200922R0001 | S2C-S/H6R Signal / Auxiliary Contact | S2C-S/H6R | 2 | piece |
| 2CDS200946R0001 | S2C-H6-11R Auxiliary Contact | S2C-H6-11R | 1 | piece |
| 2CDS200946R0003 | S2C-H6-02R Auxiliary Contact | S2C-H6-02R | 1 | piece |
| 2CDS200946R0002 | S2C-H6-20R Auxiliary Contact | S2C-H6-20R | 1 | piece |
| 2CSS200933R0011 | F2C-A1 Shunt trip | F2C-A1 | 1 | piece |
| 2CSS200933R0012 | F2C-A2 Shunt trip | F2C-A2 | 1 | piece |
| 2CSS200911R0005 | S2C-UA 230 AC Undervoltage Release | S2C-UA 230 AC | 1 | piece |
| 2CSS200911R0007 | S2C-UA 24 DC Undervoltage Release | S2C-UA 24 DC | 1 | piece |
| 2CSS200911R0002 | S2C-UA 24 AC Undervoltage Release | S2C-UA 24 AC | 1 | piece |
| 2CSS200911R0008 | S2C-UA 48 DC Undervoltage Release | S2C-UA 48 DC | 1 | piece |
| 2CSS200911R0004 | S2C-UA 110 AC Undervoltage Release | S2C-UA 110 AC | 1 | piece |
| 2CSS200911R0006 | S2C-UA 400 AC Undervoltage Release | S2C-UA 400 AC | 1 | piece |
| 2CSS200911R0001 | S2C-UA 12 DC Undervoltage Release | S2C-UA 12 DC | 1 | piece |
| 2CSS200911R0010 | S2C-UA 230 DC Undervoltage Release | S2C-UA 230 DC | 1 | piece |
| 2CSS200911R0009 | S2C-UA 110 DC Undervoltage Release | S2C-UA 110 DC | 1 | piece |
| 2CSS200911R0003 | S2C-UA 48 AC Undervoltage Release | S2C-UA 48 AC | 1 | piece |
| 2CSS200910R0005 | S2C-OVP1 Overvoltage Release | S2C-OVP1 | 1 | piece |
| 2CSS200993R0005 | S2C-OVP2 Overvoltage Release | S2C-OVP2 | 1 | piece |
| 2CSF200997R0013 | F2C-CM Motor operating device | F2C-CM | 1 | piece |
| 2CSF200996R0013 | F2C-ARI Auto-reclosing unit | F2C-ARI | 1 | piece |
| 2CSF200995R0013 | F2C-ARI30 Auto-reclosing unit | F2C-ARI30 | 1 | piece |
| 2CSF200990R0005 | F2C-ARH100 Auto-reclosing unit | F2C-ARH100 | 1 | piece |
| 2CSF200989R0005 | F2C-ARH -T100 Auto-reclosing unit with autotest | F2C-ARH - T100 | 1 | piece |

Categories

Low Voltage Products and Systems \rightarrow Modular DIN Rail Products \rightarrow Residual Current Devices RCDs \rightarrow Residual Current Devices RCDs

