



PRODUCT-DETAILS

XT4L 250 TMA 200-2000 4p F F InN=50%

XT4L 250 TMA 200-2000 4p F F InN=50%



General Information

Extended Product Type	XT4L 250 TMA 200-2000 4p F F InN=50%
Product ID	1SDA068390R1
EAN	8015644022969
Catalog Description	XT4L 250 TMA 200-2000 4p F F InN=50%
Long Description	C.BREAKER TMAX XT4L 250 FIXED FOUR-POLE WITH FRONT TERMINALS AND THERMOMAGNETIC RELEASE TMA R 200 I3=1000...2000 A NEUTRAL = 50% PHASES

ABB EcoSolutions

ABB EcoSolutions	Yes
------------------	-----

Circular Value

Circular Design Principles	Design for Closing Resource Loops - Standard EN45555 - 56.30 %
Recyclability Rate	
Conflict Minerals Reporting Template (CMRT)	9AKK108467A5658
End of Life Instructions	9AKK108468A2351

Group Waste to Landfill Target	UL 2799 Zero Waste To Landfill Validation available
Toxic Substances Control Act - TSCA	9AKK108467A8326

Eco Transparency

Environmental Product Declaration - EPD	9AKK108469A1857 9AKK108468A1892
---	------------------------------------

Environmental

Environmental Information	9AKK108467A6707
REACH Declaration	9AKK108466A1425
RoHS Information	9AKK108466A1424
RoHS Status	Following EU Directive 2011/65/EU and Amendment 2015/863 July 22, 2019

Ordering

Order Code US and Canada	XT4LEN200BFF000XXX
EAN	8015644022969
Minimum Order Quantity	1 piece
Customs Tariff Number	85362090

Dimensions

Product Net Width	140 mm
Product Net Height	160 mm
Product Net Depth / Length	82.5 mm
Product Net Weight	3.5 kg

Container Information

Package Level 1 Units	box 1 piece
Package Level 1 Width	145 mm
Package Level 1 Height	210 mm
Package Level 1 Depth / Length	168 mm
Package Level 1 Gross Weight	3.5 kg
Package Level 1 EAN	8015644022969

Additional Information

Circuit Breaker Type to be Associated	Power Distribution
Connecting Capacity Main Circuit	Busbar 85..200 mm²
Current Type	AC/DC
Electrical Durability	120 cycles per hour 8000 cycle
Mechanical Durability	240 cycles per hour 25000 cycle
Number of Poles	4
Opening Time	CB with SOR 15 ms

	CB with UVR 15 ms
Order Multiple	1 piece
Power Loss	at Rated Operating Conditions per Pole 11.88 W
Product Main Type	SACE Tmax XT
Product Name	Moulded Case Circuit Breaker
Product Type	Automatic Circuit Breaker
Rated Current (I _n)	200 A
Rated Frequency (f)	50 / 60 Hz
Rated Voltage (U _r)	690 V
Rated Impulse Withstand Voltage (U _{imp})	8 kV
Rated Instantaneous Short-Circuit Current Setting (I _s)	1000...2000 A
Rated Insulation Voltage (U _i)	1000 V
Rated Operational Voltage	690 V AC 750 V DC
Rated Service Short-Circuit Breaking Capacity (I _{cs})	(220 V AC) 150 kA (230 V AC) 150 kA (240 V AC) 150 kA (380 V AC) 120 kA (415 V AC) 120 kA (440 V AC) 100 kA (500 V AC) 60 kA (525 V AC) 50 kA (690 V AC) 20 kA (250 V DC) 2 Poles in Series 85 kA (500 V DC) 2 Poles in Series 85 kA (500 V DC) 3 Poles in Series 85 kA
Rated Ultimate Short-Circuit Breaking Capacity (I _{cu})	(220 V AC) 150 kA (230 V AC) 150 kA (240 V AC) 150 kA (380 V AC) 120 kA (415 V AC) 120 kA (440 V AC) 100 kA (500 V AC) 60 kA (525 V AC) 50 kA (690 V AC) 20 kA (250 V DC) 2 Poles in Series 85 kA (500 V DC) 2 Poles in Series 85 kA (500 V DC) 3 Poles in Series 85 kA
Rated Uninterrupted Current (I _u)	250 A
Recommended Screw Driver	Main Circuit M8
Release	TMA
Release Type	TM
Setting Range	140...200 A
Short-Circuit Performance Level	L
Standards	IEC60947-2
Sub-type	XT4
Terminal Connection Type	Front
Terminal Type	Bolt
Tightening Torque	8 N·m
Version	F
CAD Dimensional Drawing	1SDH001295R0677

Certificates and Declarations

ATEX Certificate	No certification needed
Data Sheet, Technical Information	1SDC210100D0206 1SDC210099D0206
Declaration of Conformity	9AKK106713A5529

- CE	
GL Certificate	1SDL000163R0095
LR Certificate	1SDL000163R0100
UL Certificate	No certification needed
VDE Certificate	No certification needed
Dimension Diagram	1SDH000722R0100
Mechanical Drawings	1SDH000722R0100
Wiring Diagram	1SDM000068R0001
Instructions and Manuals	1SDH000722R0001

Classifications	
ETIM 7	EC000228 - Power circuit-breaker for trafo/generator/installation protection
ETIM 8	EC000228 - Power circuit-breaker for trafo/generator/installation protection
ETIM 9	EC000228 - Power circuit-breaker for trafo/generator/installation protection
Object Classification Code	Q
UNSPSC	39120000
WEEE Category	5. Small Equipment (No External Dimension More Than 50 cm)
eClass	V11.1 : 27370409

Categories
Low Voltage Products and Systems → Circuit Breakers → Moulded Case Circuit Breakers → Tmax XT

