



PRODUCT-DETAILS

XT4L 250 TMA 225-2250 4p F F InN=100%

XT4L 250 TMA 225-2250 4p F F InN=100%



General Information	
Extended Product Type	XT4L 250 TMA 225-2250 4p F F InN=100%
Product ID	1SDA068396R1
EAN	8015644023027
Catalog Description	XT4L 250 TMA 225-2250 4p F F InN=100%
Long Description	C.BREAKER TMAX XT4L 250 FIXED FOUR-POLE WITH FRONT TERMINALS AND THERMOMAGNETIC RELEASE TMA R 225 I3=1125...2250 A FULLY RATED NEUTRAL

ABB EcoSolutions	
ABB EcoSolutions	Yes

Circular Value	
Circular Design	Design for Closing Resource Loops - Standard EN45555 - 56.30 %
Principles Recyclability Rate	
Conflict Minerals Reporting Template	9AKK108467A5658

(CMRT)

End of Life Instructions	9AKK108468A2351
Group Waste to Landfill Target	UL 2799 Zero Waste To Landfill Validation available
Toxic Substances Control Act - TSCA	9AKK108467A8326

Eco Transparency

Environmental Product Declaration - EPD	9AKK108469A1857
	9AKK108468A1892

Environmental

Environmental Information	9AKK108467A6707
REACH Declaration	9AKK108466A1425
RoHS Information	9AKK108466A1424
RoHS Status	Following EU Directive 2011/65/EU and Amendment 2015/863 July 22, 2019

Ordering

Order Code US and Canada	XT4LE4225BFF000XXX
EAN	8015644023027
Minimum Order Quantity	1 piece
Customs Tariff Number	85362090

Dimensions

Product Net Width	140 mm
Product Net Height	160 mm
Product Net Depth / Length	82.5 mm
Product Net Weight	3.5 kg

Container Information

Package Level 1 Units	box 1 piece
Package Level 1 Width	145 mm
Package Level 1 Height	210 mm
Package Level 1 Depth / Length	168 mm
Package Level 1 Gross Weight	3.5 kg
Package Level 1 EAN	8015644023027

Additional Information

Circuit Breaker Type to be Associated	Power Distribution
Connecting Capacity Main Circuit	Busbar 85..200 mm²

Current Type	AC/DC
Electrical Durability	120 cycles per hour 8000 cycle
Mechanical Durability	240 cycles per hour 25000 cycle
Number of Poles	4
Opening Time	CB with SOR 15 ms CB with UVR 15 ms
Order Multiple	1 piece
Power Loss	at Rated Operating Conditions per Pole 16.4 W
Product Main Type	SACE Tmax XT
Product Name	Moulded Case Circuit Breaker
Product Type	Automatic Circuit Breaker
Rated Current (I_n)	225 A
Rated Frequency (f)	50 / 60 Hz
Rated Voltage (U_r)	690 V
Rated Impulse Withstand Voltage (U_{imp})	8 kV
Rated Instantaneous Short-Circuit Current Setting (I_i)	1125...2250 A
Rated Insulation Voltage (U_i)	1000 V
Rated Operational Voltage	690 V AC 750 V DC
Rated Service Short- Circuit Breaking Capacity (I_{cs})	(220 V AC) 150 kA (230 V AC) 150 kA (240 V AC) 150 kA (380 V AC) 120 kA (415 V AC) 120 kA (440 V AC) 100 kA (500 V AC) 60 kA (525 V AC) 50 kA (690 V AC) 20 kA (250 V DC) 2 Poles in Series 85 kA (500 V DC) 2 Poles in Series 85 kA (500 V DC) 3 Poles in Series 85 kA
Rated Ultimate Short- Circuit Breaking Capacity (I_{cu})	(220 V AC) 150 kA (230 V AC) 150 kA (240 V AC) 150 kA (380 V AC) 120 kA (415 V AC) 120 kA (440 V AC) 100 kA (500 V AC) 60 kA (525 V AC) 50 kA (690 V AC) 20 kA (250 V DC) 2 Poles in Series 85 kA (500 V DC) 2 Poles in Series 85 kA (500 V DC) 3 Poles in Series 85 kA
Rated Uninterrupted Current (I_u)	250 A
Recommended Screw Driver	Main Circuit M8
Release	TMA
Release Type	TM
Setting Range	157.5...225 A
Short-Circuit Performance Level	L
Standards	IEC60947-2
Sub-type	XT4
Terminal Connection	Front

Type	
Terminal Type	Bolt
Tightening Torque	8 N·m
Version	F
CAD Dimensional Drawing	1SDH001295R0677

Certificates and Declarations

ATEX Certificate	No certification needed
Data Sheet, Technical Information	1SDC210100D0206 1SDC210099D0206
Declaration of Conformity - CE	9AKK106713A5529
GL Certificate	1SDL000163R0095
LR Certificate	1SDL000163R0100
UL Certificate	No certification needed
VDE Certificate	No certification needed
Dimension Diagram	1SDH000722R0100
Mechanical Drawings	1SDH000722R0100
Wiring Diagram	1SDM000068R0001
Instructions and Manuals	1SDH000722R0001

Classifications

ETIM 7	EC000228 - Power circuit-breaker for trafo/generator/installation protection
ETIM 8	EC000228 - Power circuit-breaker for trafo/generator/installation protection
ETIM 9	EC000228 - Power circuit-breaker for trafo/generator/installation protection
Object Classification Code	Q
UNSPSC	39120000
WEEE Category	5. Small Equipment (No External Dimension More Than 50 cm)
eClass	V11.1 : 27370409

Categories

Low Voltage Products and Systems → Circuit Breakers → Moulded Case Circuit Breakers → Tmax XT

