

IEC**IECEE**

Ref. Certif. No.

FR_720889

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Socket-outlet for fixed-electrical installations

Name and address of the applicant

LEGRAND FRANCE
128 AVENUE DU MARECHAL DE LATTRE DE TASSIGNY
87045 LIMOGES CEDEX
FRANCE

Name and address of the manufacturer

LEGRAND FRANCE
128 AVENUE DU MARECHAL DE LATTRE DE TASSIGNY
87045 LIMOGES CEDEX
FRANCE

Name and address of the factory

LEGRAND FRANCE
128 AVENUE DU MARECHAL DE LATTRE DE TASSIGNY
87045 LIMOGES CEDEX
FRANCE

Note: When more than one factory, please report on page 2

 Additional Information on page 2

Ratings and principal characteristics

See Annex

Trademark / Brand (if any)



Customer's Testing Facility (CTF) Stage used

/

Model / Type Ref.

See Annex

Additional information (if necessary may also be reported on page 2)

Supersedes CBTC FR_700198 dated 09/02/2017. Update further to the evolution of the standard(s)

 Additional Information on page 2

A sample of the product was tested and found to be in conformity with

IEC 60884-1:2022

As shown in the Test Report Ref. No. which forms part of this Certificate

21616807-798770

This CB Test Certificate is issued by the National Certification Body

LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE
33 avenue du Général Leclerc
92260 Fontenay-aux-Roses, FRANCE
www.lcie.frSignature:
Julien GAUTHIER
Certification Officer

Date: 21/01/2025

ANNEX

References, ratings and main characteristics:

Type reference	Reference	Function	Type of terminals	Specificity
PFA1	0 042 80	2P+T / 2P+E	slt	-
	0 927 82	2P+T / 2P+E	slt	-
	0 042 83	2P+T / 2P+E	slt	with pilot light
	0 042 82	2P+T / 2P+E	st	tamperproof

slt: screwless terminals (rigid and flexible)

st: screw-type terminals

Standard sheet	V
Tension nominale / Rated voltage (V)	16 A 250 V~
Method of connecting the cable	rewirable
Degree of protection against electric shock	normal protection
Existence of shutters	With shutters
Method of application – mounting	surface type on rails EN 50022
Method of installation	design A
Degree of protection	IP20



LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE
 33 avenue du Général Leclerc
 92260 Fontenay-aux-Roses, FRANCE
www.lcie.fr

Date: 21/01/2025



Signature: **Julien GAUTHIER**
 Certification Officer