



## Certificate of Conformity

LOVAG-Certificate No.: IT 19.028 Page 1 of 2

This Certificate applies only to the apparatus verified. The responsibility for conformity of any apparatus having the same designation with that verified rests with the manufacturer or responsible vendor.

This certificate has been prepared according to LOVAG (Low Voltage Agreement Group) Objectives and Operating Principles of mutual recognition. The responsible certification body as a member of LOVAG issues a Certificate of Conformity with the above mentioned Standard(s) following the exclusive use of LOVAG Verification instruction wherever applicable.

Only integral reproduction of this Certificate or reproductions of this page accompanied by any page(s) on which are stated the verifications performed and the assigned rated characteristics of the apparatus verified, are permitted without written permission from the LOVAG Signatory responsible for this Certificate

Apparatus Low-voltage busbar trunking system

 $1000V (U_e) - 1000V (U_i) - 12kV (U_{imp}) - 50/60Hz - 400A$ , 550A,630A ( $I_{nA}$ ) - 50kA at 415V ( $I_{cc}$ ) - IP55

Designation Type XCP/XCM Tap-off box metal 400A-630A

Manufacturer BTICINO SPA - LEGRAND GROUP

Via XXV Aprile n°10, 2508 Castrezzone-Muscoline (BS)

Applicant: BTICINO SPA –LEGRAND GROUP

Viale Borri n°231, 21100 Varese (VA)

Verified by: ACAE Laboratory:

IB01 Varese (Italy)

IZ01 Castrezzone di Muscoline BS (Italy)

The apparatus, constructed in accordance with the description mentioned in the Reports listed in this Certificate has been subjected to the series of proving verifications in accordance with IEC 61439-6 (2012-05) and EN 61439-6 (2012-08).

The results are shown in the Reports in accordance to LOVAG. The values obtained and the general performance are considered to comply with the above Standard(s) and to justify the characteristics assigned by the manufacturer.





PRD N°070B
Signatory of EA, IAF and ILAC
Mutual Recognition Agreements

Responsible Certification Body: ACAE Via Tito Livio, 5 – 24123 – BERGAMO (Italy)

Authorized Signature: Virginio Scarioni

Date: 10.06.2019







## **Certificate**

## of Conformity

LOVAG-Certificate No.: IT 19.028 Page 2 of 2



| Standard<br>IEC 61439-6<br>Subclause | TEST   | Test Report No.      |
|--------------------------------------|--|----------------------|
| 10.2.6                               | Protection against mechanical impact                                   | 1327-3               |
| 10.2.102                             | Thermal cycling test   | 1327-3,1327-4,1327-5 |
| 10.4                                 | Clearances and creepage distances                                      | 1327-3               |
| 10.5                                 | Protection against electric shock and integrity of protective circuits | 1327-1               |
| 10.9.2                               | Power Frequency withstand voltage                                      | 1327-3               |
| 10.9.3                               | Impulse withstand voltage  | 1327-3               |
| 10.10                                | Temperature-rise limits  | 1327-3,1327-4,1327-5 |
| 10.11                                | Short-circuit withstand strength                                       | 1327-1               |
| 10.13                                | Mechanical strength/operation  | 1327-3               |
| 10.2.2                               | Resistance to corrosion<br>Severity test A                             | 1327-2               |
| 10.2.3.1                             | Thermal stability of enclosures  | 1327-2               |
| 10.2.3.2                             | Abnormal heat and fire due to internal electric effects                | 1327-2               |
| 10.2.7                               | Marking  | 1327-2               |
| 10.3                                 | Degree of protection of enclosures IP55                                | 1327-2               |

## \* Version tested :

Tap off box metal with fuses NH2 Type: Inc =400A Tap off box metal with fuses NH3 Type: Inc =550A

Tap off box metal with circuit breaker DPX3 Type : Inc =550A

Tap off box metal empty: Inc =630A

This document includes:

Test Report No.:1327-1 Issue Date: 2018.12.11 Test Report No.: 1327-2 Issue Date: 2019.04.05 Test Report No.: 1327-3 Issue Date: 2019.04.05 Test Report No.: 1327-4 Issue Date: 2019.04.05 Test Report No.: 1327-5 Issue Date: 2019.04.05

> Responsible Certification Body: ACAE Via Tito Livio, 5 \(\pm\$24123 - BERGAMO\) (Italy)

ACCREDIA S

PRD N°070B Signatory of EA, IAF and ILAC Mutual Recognition Agreements

Authorized Signature: Virginio Scarioni

Date: 10.06.2019