Ref. Certif. No.
NL-56461

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product	Luminaire for emergency lighting with LED light source
Name and address of the applicant	Cooper Securite SAS Rue Beethoven 63204 Riom France
Name and address of the manufacturer	Cooper Csa S.r.l. Via San Bovio,3 – Edificio Y 20090 Segrate (MI) Italy
Name and address of the factory Note: *When more than one factory, please report on page 2*	☐ Additional information on page 2 SC Cooper Industries Romania SRL Zona Industriala Vest Strada III, Nr. 12 310510 Arad Romania
Ratings and principal characteristics	230 V, 50/60 Hz, LED module, duration 60 or 180 minutes. Class II; IP40 or IP65
Trademark (if any)	EATON
Customer's Testing Facility (CTF) Stage used	
Model / Type Ref.	NXL100, NXL100-IP, NXL150, NXL150-IP, NXL250, NXL250-IP NXL150-3H,NXL250-3H
Additional information (if necessary may also be reported on page 2)	☐ Additional information on page 2 The luminaire can be mounted on the recessed ceiling / wall by the means of accessory: NEXI-RB Recessed wall box (dimension 277 x 100 mm) NEXI- FC Kit Recessed ceiling (dimension 272 x 95 mm) This certificate replaces certificate NL-49297 which we herewith declare invalid
A sample of the product was tested and found to be in conformity with	IEC 60598-1:2014, IEC 60598-2-22:2014 National differences: EU Group Differences Comments: Report 3506326.50 covers alternative safety isolating transformer by Myrra type reference 44013 for models NXL100, NXL100-IP, NXL150, NXL150-IP, NXL250, NXL250-IP
As shown in the Test Report Ref. No. which forms part of this Certificate	3506326.50

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.
Meander 1051, NL-6825 MJ Arnhem, Netherlands

DEKRA

Firmato digitalmente da
MASSIMILIANO TRIULZI

Date: 2019-02-11

Signature: M.Triulzi