

UKCA DECLARATION OF CONFORMITY No. 23.3608.04.23

We Hager Electro SAS
BP3
67215 OBERNAI CEDEX - FRANCE

Declare that the product(s)

Designation

Switch Disconnecter HW4W, HU4W

Type reference(s)

HW4W, HU4W (See next pages)

Trademark

Hager

is (are) in conformity with the relevant United Kingdom legislation:

- SI 2016/1101 Electrical Equipment (safety) Regulations 2016 (as amended)

- SI 2016/1091 Electromagnetic Compatibility (EMC) Regulations 2016 (as amended)

- SI 2012/3032 Restriction of the Use of Certain Hazardous Substances in Electrical and Electronic Equipment Regulations 2012 (as amended)

.....

.....

Standard(s) and/or relevant document(s) to which conformity is declared

Standard number + relevant amendments together with the edition dates

BS EN IEC 60947-3: 2021
BS EN IEC 63000: 2018

If applicable, mention here for radio products, the data about notified body. See RE legislation - Annex VI - point 7

This declaration of conformity is issued under the sole responsibility of the manufacturer.

On behalf of Hager Electro SAS

Name of signatory

Eric Boivin

Function of signatory

Certification Mandatee

Place and date of issue

Obernai, 6th April 2023

Signature



UKCA DECLARATION OF CONFORMITY

No. 23.3608.04.23

Type references

HU4W310DS	Switch Disconnecter HU4 1000A 3P Drawout
HU4W310FS	Switch Disconnecter HU4 1000A 3P Fixed
HU4W312DS	Switch Disconnecter HU4 1250A 3P Drawout
HU4W312FS	Switch Disconnecter HU4 1250A 3P Fixed
HU4W316DS	Switch Disconnecter HU4 1600A 3P Drawout
HU4W316FS	Switch Disconnecter HU4 1600A 3P Fixed
HU4W320DS	Switch Disconnecter HU4 2000A 3P Drawout
HU4W320FS	Switch Disconnecter HU4 2000A 3P Fixed
HU4W325DS	Switch Disconnecter HU4 2500A 3P Drawout
HU4W325FS	Switch Disconnecter HU4 2500A 3P Fixed
HU4W332DS	Switch Disconnecter HU4 3200A 3P Drawout
HU4W332FS	Switch Disconnecter HU4 3200A 3P Fixed
HU4W340DS	Switch Disconnecter HU4 4000A 3P Drawout
HU4W340FS	Switch Disconnecter HU4 4000A 3P Fixed
HU4W410DS	Switch Disconnecter HU4 1000A 4P Drawout
HU4W410FS	Switch Disconnecter HU4 1000A 4P Fixed
HU4W412DS	Switch Disconnecter HU4 1250A 4P Drawout
HU4W412FS	Switch Disconnecter HU4 1250A 4P Fixed
HU4W416DS	Switch Disconnecter HU4 1600A 4P Drawout
HU4W416FS	Switch Disconnecter HU4 1600A 4P Fixed
HU4W420DS	Switch Disconnecter HU4 2000A 4P Drawout
HU4W420FS	Switch Disconnecter HU4 2000A 4P Fixed
HU4W425DS	Switch Disconnecter HU4 2500A 4P Drawout
HU4W425FS	Switch Disconnecter HU4 2500A 4P Fixed
HU4W432DS	Switch Disconnecter HU4 3200A 4P Drawout
HU4W432FS	Switch Disconnecter HU4 3200A 4P Fixed
HU4W440DS	Switch Disconnecter HU4 4000A 4P Drawout
HU4W440FS	Switch Disconnecter HU4 4000A 4P Fixed
HW4W310DS	Switch Disconnecter HW4 1000A 3P Drawout
HW4W310FS	Switch Disconnecter HW4 1000A 3P Fixed
HW4W312DS	Switch Disconnecter HW4 1250A 3P Drawout
HW4W312FS	Switch Disconnecter HW4 1250A 3P Fixed
HW4W316DS	Switch Disconnecter HW4 1600A 3P Drawout
HW4W316FS	Switch Disconnecter HW4 1600A 3P Fixed
HW4W320DS	Switch Disconnecter HW4 2000A 3P Drawout
HW4W320FS	Switch Disconnecter HW4 2000A 3P Fixed
HW4W325DS	Switch Disconnecter HW4 2500A 3P Drawout
HW4W325FS	Switch Disconnecter HW4 2500A 3P Fixed
HW4W332DS	Switch Disconnecter HW4 3200A 3P Drawout
HW4W332FS	Switch Disconnecter HW4 3200A 3P Fixed
HW4W340DS	Switch Disconnecter HW4 4000A 3P Drawout
HW4W340FS	Switch Disconnecter HW4 4000A 3P Fixed
HW4W410DS	Switch Disconnecter HW4 1000A 4P Drawout
HW4W410FS	Switch Disconnecter HW4 1000A 4P Fixed

UKCA DECLARATION OF CONFORMITY

No. 23.3608.04.23

Type references

HW4W412DS	Switch Disconnecter HW4 1250A 4P Drawout
HW4W412FS	Switch Disconnecter HW4 1250A 4P Fixed
HW4W416DS	Switch Disconnecter HW4 1600A 4P Drawout
HW4W416FS	Switch Disconnecter HW4 1600A 4P Fixed
HW4W420DS	Switch Disconnecter HW4 2000A 4P Drawout
HW4W420FS	Switch Disconnecter HW4 2000A 4P Fixed
HW4W425DS	Switch Disconnecter HW4 2500A 4P Drawout
HW4W425FS	Switch Disconnecter HW4 2500A 4P Fixed
HW4W432DS	Switch Disconnecter HW4 3200A 4P Drawout
HW4W432FS	Switch Disconnecter HW4 3200A 4P Fixed
HW4W440DS	Switch Disconnecter HW4 4000A 4P Drawout
HW4W440FS	Switch Disconnecter HW4 4000A 4P Fixed

UKCA DECLARATION OF CONFORMITY

No. 23.3608.04.23

Evidence(s)

Documents listed below have been developed to assure that all essential requirements of applied directive(s) are fulfilled:

If the product is not in the scope of Radio Equipment directive, fulfil table 1a, if yes fulfil table.

Table 1a Risk Assessment for Equipment without Radio	Applicable: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
Only designated standards published on GOV.UK (https://www.gov.uk/guidance/designated-standards) are used:	No
Scope and classification fully covers the product (case 1 of Hager Group risk analysis) :	Yes
Comments :	
Hager Group risk analysis: Only if there is at least one "No", then you have to explain how you cover the essential requirements and fill the document <u>DMS034433</u> - Hager Group risk analysis)	Risk Analysis SWITCH HW4

Table 1b Risk Assessment for Radio equipment	Applicable: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
Hager Group risk assessment: Fill document DMS063155	

Evidence(s) / Evidence(s)

Documents listed below have been used in order to establish the conformity to the essential requirements of the relevant directives

Certificate(s) / test report(s):	CB test certificate No. NL_86795 Test report No. 3326194.50
Mark approval(s):	No approval marks
Product documentation :	See Hager website
Comments:	None

Signature (technical design)

Name of signatory

Francis Diebold

Function of signatory

Engineering Director / Manager

Place and date of issue

Obernai, 6th April 2023

Signature

