

NJ15-30GK-SN-15M



- 15 mm non-flush
- Usable up to SIL 3 acc. to IEC 61508
- Degree of protection IP68
- ATEX-/IECEx-approvals for zone 0/1/20/21 (Ex i)
- ATEX-/IECEx-approvals for zone 2/22 (Ex ec/tc)
- 15 m connection cable














Dimensions



Technical Data


| | Normally closed (NC) |
|----------------|---|
| | NAMUR with safety function |
| s _n | 15 mm |
| | non-flush |
| Sa | 0 12.15 mm |
| | 0.4 |
| | 0.3 |
| | 0.85 |
| | up to SIL3 acc. to IEC 61508 Danger! In safety-related applications the sensor must be operated with a qualified fail safe interface from Pepperl+Fuchs, such as KFD2-SH-EX1. Consider the "exida Functional Safety Assessment" document which is available on www.pepperl-fuchs.com as an integral part of this product's documentation. |
| | 2-wire |
| | |
| | |
| | 18 mm |
| | 30 mm |
| | |

Refer to "General Notes Relating to Pepperl+Fuchs Product Information".


Release date: 2025-06-13 Date of issue: 2025-06-17 Filename: 70133156_eng.pdf

| Technical Data | | |
|--|----------------|--|
| 0 | | 45 *** |
| C | | 45 mm |
| F | | 90 mm |
| Nominal voltage | U _o | 8.2 V (R_i approx. 1 k Ω) |
| Switching frequency | f | 0 100 Hz |
| Current consumption | | |
| Measuring plate not detected | | ≥3 mA |
| Measuring plate detected | | ≤1 mA |
| Functional safety related parameters | | |
| Safety Integrity Level (SIL) | | SIL 3 |
| MTTF _d | | 11850 a |
| Mission Time (T _M) | | 20 a |
| Diagnostic Coverage (DC) | | 0 % |
| Compliance with standards and directives | | |
| Standard conformity | | |
| NAMUR | | EN 60947-5-6:2000 IEC 60947-5-6:1999 |
| Standards | | EN IEC 60947-5-2 |
| Approvals and certificates | | |
| IECEx approval | | |
| Equipment protection level Ga | | IECEx PTB 11.0092X |
| Equipment protection level Gb | | IECEx PTB 11.0092X |
| Equipment protection level Gc (ec) | | IECEx TUR 21.0017X |
| Equipment protection level Da | | IECEx PTB 11.0092X |
| Equipment protection level Dc (tc) | | IECEx TUR 21.0018X |
| Equipment protection level Mb | | IECEx PTB 11.0092X |
| ATEX approval | | |
| Equipment protection level Ga | | PTB 00 ATEX 2049 X |
| Equipment protection level Gb | | PTB 00 ATEX 2049 X |
| Equipment protection level Gc (ec) | | TÜV 20 ATEX 8523 X |
| Equipment protection level Da | | PTB 00 ATEX 2049 X |
| Equipment protection level Dc (tc) | | TÜV 20 ATEX 8524 X |
| UL approval | | cULus Listed, General Purpose |
| Ordinary Location | | E87056 |
| Hazardous Location | | E501628 |
| Control drawing | | 116-0454 |
| CCC approval | | |
| Hazardous Location | | 2020322315002308 2024322315005947 2024322315005860 |
| Ambient conditions | | |
| Ambient temperature | | -40 100 °C (-40 212 °F) |
| Mechanical specifications | | |
| Connection type | | cable |
| Housing material | | Crastin (PBT), black |
| Sensing face | | Crastin (PBT), black |
| Degree of protection | | IP68 |
| Cable | | |
| Cable diameter | | 6 mm ± 0.2 mm |
| Bending radius | | > 10 x cable diameter |
| Material | | silicone |
| Core cross section | | 0.75 mm ² |
| | L | 15 m |
| Length Dimensions | L | 13 111 |
| | | 40 mm |
| Length | | 40 mm |

Connection Assignment



Installation Conditions



Application

Danger!

In safety-related applications the sensor must be operated with a qualified fail safe interface from Pepperl+Fuchs, such as KFD2-SH-EX1.

Consider the "exida Functional Safety Assessment" document which is available on www.pepperl-fuchs.com as an integral part of this product's documentation.