



# TYPE APPROVAL CERTIFICATE

Certificate no.:  
**TAE00003NU**  
Revision No:  
**1**

---

## This is to certify:

**that the Enclosure for Electrical Equipment**

with type designation(s)  
**PK**

issued to

**Rittal GmbH & Co. KG**  
**Herborn, Hessen, Germany**

is found to comply with

**DNV rules for classification – Ships, offshore units, and high speed and light craft**

## Application:

**Product(s) approved by this certificate is/are accepted for installation on all vessels classed by DNV.**

Issued at **Hamburg** on **2024-10-15**

This Certificate is valid until **2029-09-26**.

for **DNV**

DNV local unit: **Essen**

Approval Engineer: **Harald Amberger**

This Certificate is subject to terms and conditions overleaf. Any significant change in design or construction may render this Certificate invalid.  
The validity date relates to the Type Approval Certificate and not to the approval of equipment/systems installed.

LEGAL DISCLAIMER: Unless otherwise stated in the applicable contract with the holder of this document, or following from mandatory law, the liability of DNV AS, its parent companies and their subsidiaries as well as their officers, directors and employees ("DNV") arising from or in connection with the services rendered for the purpose of the issuance of this document or reliance thereon, whether in contract or in tort (including negligence), shall be limited to direct losses and under any circumstance be limited to USD 300 000.



Form code: TA 251

Revision: 2023-09

www.dnv.com

Page 1 of 2

## Product description

### Junction Box Type PK

Polycarbonate enclosures PK with knockouts in grey or without knockouts with grey or transparent cover

Material: fiber-glass reinforced polycarbonate

Sealing: Polyurethane

Range of enclosures:

	Width	Length	Depth
Minimum:	52	50	35
Maximum:	361	254	165

Version:

with metric knockouts, cover grey

without knockouts, cover: grey

without knockouts, cover: transparent

Halogen-free

Rated insulation voltage AC :  $U_i=690V$ , DC :  $U_i=1000V$

Ingress protection : IP66

Impact resistance : IK08

## Application/Limitation

Location Classes:

Temperature: A, Humidity: A, Vibration: B

Operating instruction of the manufacturer to be observed

## Type Approval documentation

### Tests carried out

IEC 60670-22, damp heat, vibration, flame retardancy V-2 acc. UL 94, 5 inch flame acc. UL746C.

## Marking of product

Rittal - Type designation - Main data.

## Periodical assessment

The scope of the periodical assessment is to verify that the conditions stipulated for the Type approval are complied with and that no alterations are made to the product design or choice of materials.

The main elements of the assessment are:

- Inspection on factory samples, selected at random from the production line (where practicable)
- Results from Routine Tests (RT) checked (if not available tests according to RT to be carried out)
- Review of type approval documentation
- Review of possible change in design, materials and performance
- Ensuring traceability between manufacturer's product type marking and Type Approval Certificate.

Periodical assessment is to be performed after 2 years and after 3.5 years. A renewal assessment will be performed at renewal of the certificate.

END OF CERTIFICATE